

**BUREAU OF FIRE PREVENTION  
TOWNSHIP OF OCEAN - FIRE DISTRICT 1  
72 LARKIN PLACE  
OAKHURST, NEW JERSEY 07755**

**CRAIG FLANNIGAN  
FIRE MARSHAL**

**OFFICE: 732-222-2624  
FAX: 732-229-7326**

**FIRE SAFETY REGULATIONS FOR COOKING IN TOWNSHIP PARKS**

FIRE SAFETY REGULATIONS ARE ENFORCED BY THE BUREAU OF FIRE PREVENTION FIRE DISTRICT # 1

The regulations are as follows:

**LPG (PROPANE) TANKS AND RELATED EQUIPMENT**

Maximum tank size shall be 100 pounds

Regulators shall be located at the tank

All tanks must have warning label reading 'Flammable Gas', followed by the word 'PROPANE'

All hoses, fittings and clamps shall be listed for LPG use

All tanks shall be secured by metal stakes and chains or other noncombustible type of securing devices No LPG tanks shall be located inside of tents or canopies

All tanks shall be in good condition, not dented or rusted

All tanks shall have up to date required tests

Tanks shall be located a minimum of 5 feet from the cooking appliance

There shall be no more than 2 LPG tanks at each location

All LPG hoses shall be located as to prevent them from being damaged

The use of residential grills is not permitted

**CANOPIES AND TENTS**

All canopies and tents shall be tested and Certified Flame Retardant a copy of the Flame Retardant Certificate must be supplied No plastic or fabric materials that are not certified flame retardant will be allowed

**FIRE EXTINGUISHERS**

A minimum of one 5-pound ABC rated fire extinguisher with an up to date inspection tag must be provided for all temporary cooking operations