

**BUREAU OF FIRE PREVENTION
TOWNSHIP OF OCEAN - FIRE DISTRICT 1
72 LARKIN PLACE
OAKHURST, NEW JERSEY 07755**

FIRE SAFETY REGULATIONS FOR FESTIVALS, FAIRS ETC.

**FIRE SAFETY REGULATIONS ARE ENFORCED BY THE
BUREAU OF FIRE PREVENTION FIRE DISTRICT NO. 1.**

LPG (PROPANE) TANKS AND RELATED EQUIPMENT

Maximum tank size shall be 100 pounds.

Regulators shall be located at the tank.

All tanks to have warning label reading '**FLAMMABLE GAS**', followed by the word '**PROPANE**'.

All hoses, fittings and clamps shall be listed for LPG use.

All tanks shall be secured by metal stakes and chains or other noncombustible type of securing devices.

No LPG tanks shall be located inside of tents or canopies.

All tanks shall be in good condition, not dented or rusted.

All tanks shall have up to date required tests.

Tanks shall be located a minimum of 5 feet from the cooking appliance.

The location of LPG tanks shall be checked by inspectors and any deemed unsafe shall be removed.

There shall be no more than two LPG tanks at each location.

All LPG hoses shall be located as to prevent them from being damaged.

The use of residential grills is not permitted.

Suitable barricades shall be provided to maintain a distance of 5 feet between the appliance and the public.

CANOPIES, TENTS AND BOOTHS

All canopies on booths or tent type booths shall be tested and certified Flame Retardant. Proof of Certification to be supplied.

Any wood booths shall be constructed of fire rated lumber.

No plastic or fabric material canopies that are not Certified Flame Retardant will be allowed.

There shall be a 5 foot minimum separation between canopies or tents.

FLAMMABLE AND COMBUSTIBLE LIQUIDS

Gasoline shall be contained in an approved metal safety cans, maximum size of five (5) gallons.

All cans shall be red in color and properly marked '**GASOLINE**'.

Kerosene containers shall be blue in color and marked '**KEROSENE**'.

Gasoline and Kerosene containers shall be stored in a safe location, away from generators, LPG tanks, and cooking appliances.

When refueling generators or other appliances, they shall be shut down, and then refueled.

(OVER)

FIRE EXTINGUISHERS

All booths shall have a minimum of one five pound ABC Rated Fire Extinguisher with an up to date inspection tag.

All booths with fryers shall also have, 1 Class K Wet Chemical Extinguisher.

If the inspectors determine that more than one extinguisher is required in a booth, the extinguisher shall be installed by the vendor.

All fire extinguishers shall have a current inspection tag and be in good condition.

FIRE EXTINGUISHING SYSTEMS IN TRAILERS

Fire extinguishing systems installed in trailers shall be inspected and maintained on 6 month intervals.

All hood and vent fan systems shall be kept clean, with filters in place at all times.

GENERATORS

Generators shall be located a minimum of 20 feet from any tent or canopy.

Generators must be isolated from the public with an approved fence.

When refueling, all generators shall be shut down.

One five pound BC Rated Fire Extinguisher shall be provided in the area of the generator.

See section on Flammable Liquids for information on fuel storage and use.

All vendors MUST sign below indicating they understand all of the above requirements.

I _____ understand all requirements set forth by the State of New Jersey, Uniform Fire Safety Act. All vendors who fail to meet all said requirements will not be permitted to operate until all requirements are meet.

Signature _____

Date _____